



AC 063

CENTRUM NAUKOWO-BADAWCZE
OCHRONY PRZECIWOŻAROWEJ
im. Józefa Tuliszowskiego
PAŃSTWOWY INSTYTUT BADAWCZY

ul. Nadwiślańska 213, 05-420 Józefów k/Otwocka



CERTIFICATE OF ADMITTANCE

No. 5202/2023

Based on art. 7 paragraph 2 of the Act of 24 August 1991 on fire protection
Centrum Naukowo-Badawcze Ochrony Przeciwożarowej im. Józefa Tuliszowskiego
Państwowy Instytut Badawczy at the request of:

Hybryd Sp. z o.o.
ul. Sikorskiego 28
44-120 Pyskowice

states that product:

Emergency lighting luminaire type PRIMOS III, PRIMOS III SGN
Varieties of the luminaire are given on page 2 of the certificate of admittance.

manufactured by:

Hybryd Sp. z o.o.
ul. Sikorskiego 28
44-120 Pyskowice

in the manufacturing plant:

Hybryd Sp. z o.o.
ul. Sikorskiego 28
44-120 Pyskowice

meets the requirements of:

p. 13.2 of annex to the Regulation of the Minister of the Interior and Administration of 20 June 2007 on the list of products used for ensuring public safety or protecting health, life and property, and the principles of issuing admittance to use these products (Polish Journal of Laws: Dz. U. nr 143 poz. 1002; zm.: Dz. U. z 2010 r. nr 85, poz. 553, z 2018 r. poz. 984, z 2022 r. poz. 2282)

Documentation:

1. Application for the process of product admittance No. 6754/2023 of 02.01.2023.
2. Test report No. 1302/BA/23 of 07.12.2023 prepared by Zespół Laboratoriów Sygnalizacji Alarmu Pożaru i Automatyki Pożarniczej (BA) CNBOP-PIB.

The certificate of admittance is valid under the condition that the applicant fulfils the requirements defined in the agreement No. 5202/DC/CNBOP-PIB/2023.

Validity period of the admittance:

from **19.12.2023**

until **18.12.2028**

DIRECTOR OF CNBOP-PIB

pp


Deputy Director for Certification and Admittance
st. bryg. inż. Jacek Zboina, D.Sc. Eng.



Józefów: 19 December 2023

*This document was originally translated from Polish to English on 3 November 2025.
In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.*



AC 063

CENTRUM NAUKOWO-BADAWCZE
OCHRONY PRZECIWPOŻAROWEJ

im. Józefa Tuliszewskiego

PAŃSTWOWY INSTYTUT BADAWCZY

ul. Nadwiślańska 213, 05-420 Józefów k/Otwocka



CERTIFICATE OF ADMITTANCE

No. 5202/2023

TECHNICAL DATA IDENTIFYING THE PRODUCT

Emergency lighting luminaire type PRIMOS III, PRIMOS III SGN in varieties:

Name	Variant	Optics type	Power of the light source	Execution	Emergency operating time	Operating mode	Range of operating temperatures	Colour temperature	Housing colour
PRIMOS III	0000 0001	AP	2W	ST	1h 3h 8h*	SM NM	TS TE	CW NW WW	9016 9005 7016 7042
		AR	3W	AT					
		RP	5W	CT					
		RO	7W	CTBT					
		RPHV	10W	CTRF					
		LD		CTW					
CLA									
PRIMOS III	0000 0001	AP	2W	CB	X	X	TS TE	CW NW WW	9016 9005 7016 7042
		AR	3W	CBAM					
		RP	5W	LVAM					
		RO	7W						
		RPHV	10W						
		LD							
CLA									

* występuje jedynie z wariantami o mocy 2W, 3W

Name	Variant	Type of luminaire	Execution	Emergency operating time	Operating mode	Range of operating temperatures	Energy mode	Housing colour	Safety sign
PRIMOS III SGN	0000 0001	SS DS	ST	1h 3h 8h	M NM SM	TS TE	E X	9016 9005 7016 7042	S
			AT						NOP
			CT						P03
			CTBT						P04
			CTRF						P55
CTW	P56								
PRIMOS III SGN	0000 0001	SS DS	CB	X	X	TS TE	X	9016 9005 7016 7042	PI05
			CBAM						PI06
			LVAM						PI15
									PI17
									PI18
									PI21
									PI22
									PI23
									PI24
									PI25
									PI26
									PI27

Note!

For double-sided luminaires, the safety symbol may appear in the column as, for example, P05/06, where 05 and 06 are the codes for the individual pictograms.

DIRECTOR OF CNBOP-PIB

pp

Deputy Director for Certification and Admittance
st. bryg. inż. Jacek Zboina, D.Sc. Eng.



Józefów: 19 December 2023

This document was originally translated from Polish to English on 3 November 2025.

In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.



AC 063

CENTRUM NAUKOWO-BADAWCZE
 OCHRONY PRZECIWPOŻAROWEJ
 im. Józefa Tuliszewskiego
 PAŃSTWOWY INSTYTUT BADAWCZY
 ul. Nadwiślańska 213, 05-420 Józefów k/Otwocka



CERTIFICATE OF ADMITTANCE

No. 5202/2023

TECHNICAL DATA IDENTIFYING THE PRODUCT

Emergency lighting luminaire type PRIMOS III, PRIMOS III SGN

Varieties of the luminaire are given on page 2 of the certificate of admittance.

Type	PRIMOS III, PRIMOS III SGN	
	Z - central supply (varieties: CB, CBAM, LVAM)	X - self-contained (varieties: ST, AT, CT, CTBT, CTRF, CTW)
Operation mode:	0 - non-maintained 1 - maintained	0 - non-maintained 1 - maintained
Accessories	E - with a non-replaceable bulb G - internally illuminated safety sign (varieties: PRIMOS III SGN)	A - including test device B - including remote sleep mode C - including lock mode E - with a non-replaceable bulb F - automatic test gear complying with IEC 61347-2-7 denoted EL-T G - internally illuminated safety sign (varieties: PRIMOS III SGN)
Rated emergency operating time	not applicable (parameter of power systems)	60 - 1 hour of emergency operating time 180 - 3 hours of emergency operating time 480 - 8 hours of emergency operating time
Rated supply voltage	230 V AC 50±60 Hz; 170÷275 V DC 24±48 V DC (varieties: LVAM)	230 V AC 50±60 Hz
Protection class against electric shock	II III (varieties: LVAM)	
Ingress protection rating to dust, solids and water	IP65	
Light source	LED module	
Battery charging time	not applicable (parameter of power systems)	not exceeding 24 h
Battery charging indication	not applicable (parameter of power systems)	yes – LED light
Adapted to pictograms	yes (varieties: PRIMOS III SGN)	
Mounting method	surface, recessed, hanging	
Mounting surface (in accordance with PN-EN 60598-1)	normally flammable surfaces	
Conditions of use (in accordance with PN-EN 60598-1)	for normal use	
Material of housing	plastic	
Self-contained luminaires in varieties AT, CT, CTBT, CTRF and CTW are intended for automatic testing systems in accordance with the PN-EN 62034:2012 standard.		

ADDITIONAL TERMS AND COMMENTS:

According to § 17 of the Regulation of the Minister of the Interior and Administration of 20 June 2007 on the list of products used for ensuring public safety or protecting health, life and property, and the principles of issuing admittance to use these products (Polish Journal of Laws: Dz. U. nr 143 poz. 1002; zm.: Dz. U. z 2010 r. nr 85, poz. 553, z 2018 r. poz. 984, z 2022 r. poz. 2282) a product should be marked with the marking of the admittance body and also the number of the certificate of admittance.

The following editions of the standards were used in the admittance process:

-PN-EN 60598-2-22:2015-01+AC1:2015-10+AC:2016-07+AC:2016-11+A1:2020-08

-PN-EN IEC 60598-1:2021-07

DIRECTOR OF CNBOP-PIB

pp

Deputy Director for Certification and Admittance
 st. bryg. inż. Jacek Zboina, D.Sc. Eng.



Józefów: 19 December 2023

This document was originally translated from Polish to English on 3 November 2025.

In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.