



AC 063

CENTRUM NAUKOWO-BADAWCZE
OCHRONY PRZECIWOŻAROWEJ
im. Józefa Tuliszowskiego
PAŃSTWOWY INSTYTUT BADAWCZY
ul. Nadwiślańska 213, 05-420 Józefów k/Otwocka



CERTIFICATE OF ADMITTANCE

No. 5638/2025

Based on art. 7 paragraph 2 of the Act of 24 August 1991 on fire protection
Centrum Naukowo-Badawcze Ochrony Przeciwożarowej im. Józefa Tuliszowskiego
Państwowy Instytut Badawczy at the request of:

Hybryd sp. z o.o.
ul. Sikorskiego 28
44-120 Pyskowice

states that product: **Emergency lighting luminaire type UTILIGHT SGN, UTILIGHT II SGN**
Varieties of the luminaire are given on pages 2 and 3 of the certificate of admittance.

manufactured by: **Hybryd sp. z o.o.**
ul. Sikorskiego 28
44-120 Pyskowice

in the manufacturing plant: **Hybryd sp. z o.o.**
ul. Sikorskiego 28
44-120 Pyskowice

meets the requirements of: **p. 13.2 of annex to the Regulation of the Minister of the Interior and Administration of 20 June 2007 on the list of products used for ensuring public safety or protecting health, life and property, and the principles of issuing admittance to use these products (Polish Journal of Laws: Dz. U. nr 143 poz. 1002; zm.: Dz. U. z 2010 r. nr 85, poz. 553, z 2018 r. poz. 984, z 2022 r. poz. 2282)**


Documentation:

1. Application for the process of product admittance No. 7499/2024 of 02.05.2024.
2. Test report No. B/2019/192/1÷5 of 10.07.2019, No. B/2024/281/1÷4 of 25.11.2024, No. B/2024/282/1÷5 of 25.11.2024 prepared by Laboratorium Badawcze i Wzorcujące Zakładu Badań i Atestacji „ZETOM” and test report No. 825/BA/24 of 09.01.2025 prepared by Zespół Laboratoriów Sygnalizacji Alarmu Pożaru i Automatyki Pożarniczej (BA) CNBOP-PIB.

The certificate of admittance is valid under the condition that the applicant fulfils the requirements defined in the agreement No. 5638/DC/CNBOP-PIB/2025.

Validity period of the admittance: from **15.01.2025** until **14.01.2030**

DIRECTOR OF CNBOP-PIB

pp 
Deputy Director for Certification and Admittance
st. bryg. Jacek Zboina, D.Sc. Eng.



Józefów: 15 January 2025

*This document was originally translated from Polish to English on 3 November 2025.
In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.*



AC 063

CENTRUM NAUKOWO-BADAWCZE
OCHRONY PRZECIWPOŻAROWEJ
im. Józefa Tuliszowskiego
PAŃSTWOWY INSTYTUT BADAWCZY

ul. Nadwiślańska 213, 05-420 Józefów k/Otwocka



CERTIFICATE OF ADMITTANCE

No. 5638/2025

TECHNICAL DATA IDENTIFYING THE PRODUCT

Emergency lighting luminaire type UTILIGHT SGN, UTILIGHT II SGN in varieties:


Name	Variant	Dimensions of the sign [cm]	Execution	Emergency operating time [h]	Operating mode	Housing colour	Surface finish	Fixtures	Safety sign
UTILIGHT SGN	0000 0001 0054 0154	20x10 30x15 40x20 60x30	ST AT CT DA CTW CTBT CTRF	1h 3h 8h ¹⁾	M SM ²⁾ CI ³⁾	9003	FT	C142 C145 C146 W140	Plx
UTILIGHT SGN	0000 0001 0054 0154	20x10 30x15 40x20 60x30	CB CBAM	X	X	9003	FT	C142 C145 C146 W140	Plx
UTILIGHT SGN	0000 0001 0054 0154	20x10 30x15 40x20 60x30	LV LVAM	X	X	9003	FT	C142 C145 C146 W140	Plx

¹⁾ 8-hour operating time is not available for fixtures with safety sign dimensions of 20x10cm and 60x30cm

²⁾ SM operating mode is not available for luminaires with safety sign dimensions of 20x10cm

³⁾ only for ST and CT

DIRECTOR OF CNBOP-PIB

pp 
Deputy Director for Certification and Admittance
st. bryg. Jacek Zboina, D.Sc. Eng.



Józefów: 15 January 2025

This document was originally translated from Polish to English on 3 November 2025.
In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.



AC 063

CENTRUM NAUKOWO-BADAWCZE
OCHRONY PRZECIWPOŻAROWEJ

im. Józefa Tuliszzkowskiego

PAŃSTWOWY INSTYTUT BADAWCZY

ul. Nadwiślańska 213, 05-420 Józefów k/Otwocka



CERTIFICATE OF ADMITTANCE

No. 5638/2025

TECHNICAL DATA IDENTIFYING THE PRODUCT


Emergency lighting luminaire type UTILIGHT SGN, UTILIGHT II SGN in varieties:

Name	Variant	Dimensions of the sign [cm]	Execution	Emergency operating time [h]	Operating mode	Housing colour	Safety sign
UTILIGHT II SGN	0000 0001	30x15	ST AT CT DA CTW CTBT CTRF	1h 3h 8h	M SM C ¹⁾	9016 9005 7016 7042	Plx
UTILIGHT II SGN	0000 0001	30x15	CB CBAM	X	X	9016 9005 7016 7042	Plx
UTILIGHT II SGN	0000 0001	30x15	LV LVAM	X	X	9016 9005 7016 7042	Plx

¹⁾ only for ST and CT

DIRECTOR OF CNBOP-PIB

pp


Deputy Director for Certification and Admittance
st. bryg. Jacek Zboina, D.Sc. Eng.



Józefów: 15 January 2025

*This document was originally translated from Polish to English on 3 November 2025
In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.*



AC 063

CENTRUM NAUKOWO-BADAWCZE
 OCHRONY PRZECIWPOŻAROWEJ
 im. Józefa Tuliszowskiego
 PAŃSTWOWY INSTYTUT BADAWCZY
 ul. Nadwiślańska 213, 05-420 Józefów k/Otwocka



CERTIFICATE OF ADMITTANCE

No. 5638/2025

TECHNICAL DATA IDENTIFYING THE PRODUCT

Emergency lighting luminaire type UTILIGHT SGN, UTILIGHT II SGN

Varieties of the luminaire are given on pages 2 and 3 of the certificate of admittance.

Type	UTILIGHT SGN, UTILIGHT II SGN	
	Z - central supply (varieties: CB, CBAM, LVAM)	X - self-contained (varieties: ST, AT, CT, DA, CTBT, CTRF, CTW)
Operation mode:	0 - non-maintained 1 - maintained	0 - non-maintained 1 - maintained
Accessories	E - with non-replaceable lamp G - internally illuminated safety sign	A - including test device B - including remote sleep mode C - including lock mode E - with a non-replaceable bulb F - automatic test gear complying with IEC 61347-2-7 denoted EL-T G - internally illuminated safety sign
Rated emergency operating time	not applicable (parameter of power systems)	60 - 1 hour of emergency operating time 180 - 3 hours of emergency operating time 480 - 8 hours of emergency operating time
Rated supply voltage	230V AC 50±60Hz; 170±275V DC (varieties: CBAM) 80±275V DC (varieties: CB) 10±32V DC (varieties: LVAM)	230V AC 50±60Hz
Protection class against electric shock	I (varieties UTILIGHT SGN) II (varieties UTILIGHT II SGN) III (varieties: LVAM)	
Ingress protection rating to dust, solids and water	IP40 IP54 (only variant: 0054, 0154)	
Light source	LED module	
Battery charging time	not applicable (parameter of power systems)	not exceeding 24 h
Battery charging indication	not applicable (function of power systems)	yes – LED light
Adapted to pictograms	yes	
Mounting method	surface, recessed, hanging	
Mounting surface (in accordance with PN-EN 60598-1)	normally flammable surfaces	
Conditions of use (in accordance with PN-EN 60598-1)	for normal use	
Material of housing	plastic	
<i>Self-contained luminaires AT, CT, DA, CTBT, CTRF, CTW are intended for automatic testing systems in accordance with the PN-EN 62034:2012 standard.</i>		

ADDITIONAL TERMS AND COMMENTS:

According to § 17 of the Regulation of the Minister of the Interior and Administration of 20 June 2007 on the list of products used for ensuring public safety or protecting health, life and property, and the principles of issuing admittance to use these products (Polish Journal of Laws: Dz. U. nr 143 poz. 1002; zm.: Dz. U. z 2010 r. nr 85, poz. 553, z 2018 r. poz. 984, z 2022 r. poz. 2282) a product should be marked with the marking of the admittance body and also the number of the certificate of admittance.

The following editions of the standards were used in the admittance process:

- PN-EN IEC 60598-2-22:2022-11
- PN-EN IEC 60598-1:2021-07+A11:2022-12

DIRECTOR OF CNBOP-PIB

pp. 
 Deputy Director for Certification and Admittance
 st. bryg. Jacek Zboina, D.Sc. Eng.



Józefów: 15 January 2025

This document was originally translated from Polish to English on 3 November 2025.

In case of conflict between the Polish certificate of admittance and this translation, the Polish document shall be binding.